



UK Declaration of Conformity

We, **Power Inspired Limited**, of **Unit 6, Christmas Hill Business Park, Rycote Lane, Thame, Oxfordshire, OX9 2FZ** declare that the following product(s):

VFI1500RT+, 1.5KVA Online Rack/Tower UPS
VFI3000RT+, 3KVA Online Rack/Tower UPS
BP-VFI-RT-72-18[14], 72V 18[14]Ah Rack/Tower Battery Cab
BP-VFT-RT-36-18[14], 36V 18[14]Ah Rack/Tower Battery Cab

Are in conformance with the following UK legislative requirements:

Electrical Equipment (Safety) Regulations 2016

Electromagnetic Compatibility Regulations 2016

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012

As being in accordance with the appropriate sections of following standards:

BS EN62040-1: 2008 Uninterruptible power systems (UPS). General and safety requirements for UPS

BS EN62040-2: 2006 Uninterruptible power systems (UPS). Electromagnetic compatibility (EMC) requirements

BS EN50581:2012 Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

BS EN 62321: 2009 Electrotechnical products - Determination of levels of six regulated substances

And are responsible for their continued compliance.

A handwritten signature in blue ink, appearing to read 'Tony Bell'.

Tony Bell BEng MIET
Managing Director, Power Inspired Ltd
5 September 2025